



WATER SERVICE BRANCH and METER PROCEDURES

Engineering Division/Branch Service Section



Table of Contents

General Overview1

GCWW - Laws, Ordinances, Rules, Regulations and Standard Drawing References

Governing Service Branches2

 Service Branches – 2” or smaller on dedicated right-of-way.....2

 Service Branch Applications for all size of fire branches, all portions of Dual or Tri-services, “curb-only”
 branches larger than 2”, and domestic or irrigation branches larger than 2” 3-7

Cost of Service Branches 7-8

Construction Water Prices8

Valve Prices8

Meter Prices9

Material Prices10

Curb Boxes11

Roadway Box Parts Prices11

Mason Branch Costs 11-12

Domestic Branch and Meter Sizing Table13

 Minimum Requirements: Residential.....13

 Minimum Requirements: Commercial.....14

Branch Material Data 14-15

This document provides information and instructions on applying for water service within the Greater Cincinnati Water Works service area.

GENERAL OVERVIEW

The Branch Services Section of the Greater Cincinnati Water Works (GCWW) Engineering Division coordinates the application process for new service branches. There are three different branch application processes dependent on the location and type of development. The three processes are: 1.) Subdivision “Curb Only” taps, 2” and smaller; 2.) Small branches 2” or smaller on dedicated right-of-way; 3.) All fire branches, Dual or Tri-Services, “Curb Only” branches larger than 2” and Domestic or Irrigation branches larger than 2” in size.

The "Certified Person" referred to in this document, is one who holds a State of Ohio master plumber's license and has taken the GCWW test to ensure that the applicant is familiar with our rules and regulations for installing service from the right-of-way line up to and including the meter setting or detector check setting. The test is given by appointment and you may schedule to take it by calling John Waters (513-591-7836) at least two days in advance. There is no charge for the test. However, you must purchase the GCWW Rules and Regulations manual (\$8.00) (or) go online at <http://www.cincinnati-oh.gov/water/permits-construction/records-services/laws-ordinances-rules-regulations/> and make a copy to bring with you when you take the test.

The bond that is referred to is a \$1,000 Certified Persons performance bond. The bond runs from January 1 to December 31. GCWW will provide the bond form for your insurance company to complete, or you can go online to: <http://www.cincinnati-oh.gov/water/permits-construction/branch-meter-services> and make a copy of the forms.

Payment for branches and meters is made to the GCWW Cashier in cash, check or visa prior to receipt of service. Check should be made payable to the “Greater Cincinnati Water Works”.

GCWW - LAWS, ORDINANCES, RULES, REGULATIONS AND STANDARD DRAWING REFERENCES:

BRANCHES: Sections 401-31, 32, 33, 35, 36 and 41

METERS: Sections 401-43, 51, 52, 53, 54 and 55

STANDARD DRAWINGS: 108-1 thru 109-5B

1) SUBDIVISION/ "CURB ONLY" TAPS - 2" AND SMALLER ONLY

When a new subdivision is being developed, the developer or a GCWW Certified Tapper completes a form D-100-S for each tap to be installed. All lots in the development must be provided with a tap. The SUBDIVISION BRANCH price from the rate table on page 6, only applies to these taps. In this case only materials are included (ferrule, curb stop and "blue top stake").

Insulator couplings are required and are an additional cost. The Certified Tapper performs the actual branch installation work with a GCWW Construction Inspector present. A meter is not purchased until after the individual lot is developed. (See Section 401-31R13 thru R16 and Section 401-33 of GCWW - Laws, Ordinances, Rules and Regulations for detailed requirements) GCWW Water Works Construction Inspection fees apply.

2) SERVICE BRANCHES - 2" OR SMALLER ON DEDICATED RIGHT-OF-WAY

For new service on existing dedicated streets, an issued building permit or plumbing permit must be presented at time of application. Application must be made by a plumber or fire installer who is licensed with the State of Ohio, certified with GCWW, and must have a current Certified Persons performance bond with GCWW, either as an individual or one bond for their employing company. The following is the general procedure when applying for a service branch two inches or less in size.

- 1.) The applicant must complete a CROSS-CONNECTION QUESTIONNAIRE (CCQ - blue form). This card provides GCWW with information about branch and meter size, desired branch location as well as proposed use of the new service. The branch location is specified from the nearest fire hydrant and cross street as well as the side of the street that the tap will run to. **EXAMPLE: You are building on the **west side** of Vine Street and the nearest cross street is Mitchell Avenue. Typical branch measurements would be- WEST SIDE OF VINE 105 FEET SOUTH OF THE FIRST FIRE HYDRANT SOUTH OF MITCHELL.**
- 2.) Provide a plot plan showing property lines and all easements for each tap.
- 3.) All applicable service fees are charged at this time including meter, branch and bulk fee for unmetered construction water. SEE TABLES BEGINNING ON PAGE 6 FOR PRICE LISTS. IN MOST CASES THE "ANY STREET" PRICE WILL APPLY TO THESE BRANCHES.
- 4.) After paying the cashier, the applicant picks up the meter and a "blue top" stake from our storeroom. The stake is used by the applicant to mark the actual tap location.

This process usually takes 15 to 30 minutes, depending on the number of people making application and how busy the cashiers are.

The next day the application goes to the Inspection Department for street opening permit and a field check of the tap location. Call (513) 591-7873 to inform the Tap Inspector, in the Inspection Department, that you have set the stake at the tap location. After we receive the street opening permit, the GCWW Tap Contractor will install the tap within 30 days.

3) SERVICE BRANCH APPLICATIONS FOR: All sizes of fire branches, all portions of Dual or Tri-services, “Curb-Only” branches larger than 2”, and Domestic or Irrigation branches larger than 2”.

For this variety of Branch Application, which is called a “Large Branch Application”, an appropriately licensed, certified and bonded person must fill out and sign a Cross Connection Questionnaire (CCQ) for each branch (a dual service requires two CCQ’s, a tri-service requires three CCQ’s) and submit that hard copy (which must be the actual form on cardstock, and can be obtained at the permitting counter at Greater Cincinnati Water Works, 4747 Spring Grove Avenue), along with 1 copy of a **single plan sheet** (or 2 copies, if the applicant wants a red-lined copy back) showing the entire property and the proposed branch, a copy of the issued permit, and recent flow test information. When the plan itself is approved as satisfying all GCWW requirements, the applicant must provide 4 copies of the final draft of the plan sheet to GCWW Branch Services.

✓ **Checklist for applicants:**

- **Completed and appropriately signed Cross Connection Questionnaire for each branch**
- **Copy of issued full building, plumbing or fire suppression permit**
- **Up to date and acceptably performed flow test data**
- **Calculations for each branch 4” or larger**
- **4 copies of the final form of the branch application drawing**

The Cross Connection Questionnaire (CCQ)

This must be filled out in its entirety; **every** question on it must be filled out. For a dual service branch for which the same company will be performing the work for both the domestic and the fire branches, both the fire CCQ **and** the domestic CCQ must be filled out completely. For projects where the fire and domestic branches will be taken care of by two different companies, each company must completely fill out the appropriate fire or domestic CCQ.

Each CCQ must be signed and dated by an appropriate authorized person:

A licensed, certified, fire installer, registered with GCWW, representing a company holding a current bond, may fill out and sign a CCQ for a fire only CCQ or a dual (or more) branch (which would require both a fire and a domestic CCQ). A licensed, certified plumber representing a company with a current bond may fill out a domestic CCQ for a domestic only branch, or a domestic CCQ for a domestic portion of a dual branch. The bond holder assumes the responsibility for the suitability of the applicant who is representing them.

There are materials at the permitting counter to outline our rules and regulations and help the applicant properly

fill out the CCQ. The form must be filled out in its entirety, with no questions left blank, including the **Needed Fire Flow @ 20 PSI**, which the applicants for fire service branches must obtain directly from the appropriate fire authority, and is not to be calculated by the applicant.

The Permit

A copy of an issued permit is required to approve this application. The permit may be the general building permit, a plumbing permit, or a fire-suppression (sprinkler) permit, but cannot be a permit application, or a foundation, shell, HVAC or other permit. **It cannot be just a submitted number, but must be an actual copy of the issued permit.** This can be brought in, faxed to us (513-591-7878) or emailed to ellen.betsch@gcww.cincinnati-oh.gov

Flow test

There must be current flow test data for the area where the tap is to be made. Typically two fire hydrants, one to each side of where the tap is proposed, will be flowed and gauged. This flow test must have been performed within the last three years, or the applicant will be required to perform a new flow test. If a potential applicant wants to check on this prior to application, or to assist with their design process, please call our Engineering Records Section at (513) 591-7855 or email: records.request@gcww.cincinnati-oh.gov . Please be aware that flow test data, even if obtained from GCWW, may not be acceptable to us for application purposes if there have been system changes within the last 3 to 5 years.

Contractor Performed Flow Tests

As the contractor performing the proposed flow test you are required to do the following:

- 1.) Perform a valid flow test
- 2.) Collect all test data (date, time, nozzle size, static, residual & pitot pressures, and flow in GPM)
- 3.) Submit flow test information to the Engineering Records Section.
 - a.) May be electronic or paper copy: records.request@gcww.cincinnati-oh.gov Fax (513-591-7878)
 - b.) Must include a map or sketch showing cross streets, a north arrow and which fire hydrant was flowed and which fire hydrant was gauged.

The following requirements are critical for the data to be accepted as a valid flow test:

- 1.) The hydrants which are flowed and gauged must be on the same size water main, ideally with no other water mains teed off between the hydrants used in the flow test.
- 2.) For flow tests run for large branch applications, the hydrants used for flow tests should ideally be located on either side of the location for the proposed branch.

PLEASE NOTE: GCWW valve personnel are present during the test to make sure the contractor does not damage the water distribution system. The GCWW valve personnel operate the fire hydrants and any necessary valves. They are not responsible for performing the test, or collecting data. GCWW considers the flow tests to be valid for a time period of 3-5 years. This timeframe will vary because of potential changes over time to the water distribution system where the flow test occurred.

Calculations

In order to make certain the system can provide the sustained flow that is needed for the new service; we need to see a copy of the calculations, indicating the peak flow and pressure needed. These calculations will show how the peak water demand requested on the application form was determined. This is true for all branches 4" or larger. This can be a print-out of the hydraulic calculations, a copy of part of a spreadsheet, or manual calculations. For domestic and irrigation service branches, this is typically a Fixture Unit Sheet.

Plans

Two one-sheet plan copies must be submitted with the CCQ(s). If you prefer, you may submit your revised application drawings via email to ellen.betsch@gcww.cincinnati-oh.gov. A signed hard copy of the CCQ must be submitted with the plan sheets in order for the plan to be reviewed as part of an application.

The single plan sheets must comply with the following criteria:

- 1) Meter settings are **required** to be outside of the building.
- 2) Plans must show complete property/parcel including building footprints and all edges of pavement; existing and proposed. Plan sheet must be oriented so that the North arrow is pointing to the top or to the right of the plan sheet (in the x,x quadrant).
- 3) For commercial developments, RP backflow containment devices are required on all domestic service branches; these are to be placed after the meter and immediately inside a heated structure, close in proximity to the right of way. The heated structure must be shown on the plan.
- 4) Plans must be in **engineering** or decimal scale; **not** architectural scale.
- 5) Proposed branch(es) and proposed pit must be shown graphically accurately; we require that all branches be a minimum of **10'** from hydrants and other GCWW fittings with blocking; 5' minimum from the outside of all other appurtenances or permanent features.
- 6) Dimension the distance, in round numbers from the nearest fire hydrant to the proposed tap.
- 7) **Label the dimension exactly as it is on the CCQ:** N. S. E. or W. side of STREET NAME, NUMBER feet N. S. E. or W. of NUMBER FH N. S. E. or W. of STREET NAME. Ex: *N side of Main, 130' E of 1st FH N of Eggleston.*
- 8) Label the FH: NUMBER FH N. S. E. or W. of STREET NAME. Ex. *1st FH N of Eggleston.*
- 9) There may be **no** horizontal bends from the main to the pit box.
- 10) **ALL existing and proposed utilities, utility connections, & appurtenances in the area of the proposed branch must be shown.** Call 1-800-362-2764 for OUPS "preplanning information". This must be completed by the applicant and the accuracy of the graphical depiction of the utilities, appurtenances and connections is entirely the responsibility of the applicant. During any part of the branch and

meter setting installation, any costs or damages related to utility information NOT shown on the drawing will be the legal and financial responsibility of the signatory applicant.

- 11) For taps made in State Right-of-Way areas, profiles of proposed branch, main being tapped and existing/proposed utilities/appurtenances must be provided and drawings must meet ODOT requirements
- 12) Applicant must check with municipality where tap is being made to determine whether an open-cut is appropriate for installing the branch. Bored & Cased is currently required on all large branches in areas where Hamilton County and the Ohio Department of Transportation is the permitting agency. Any bored & cased branch must include a profile of the branch on the drawing sheet, and must show the boring and receiving pits, and all crossing utilities within the right of way on the plan view.
- 13) Both sides of Right of Way must be shown, labeled and the width dimensioned. If the Right of Way is proposed; documentation from the appropriate authority must be provided, verifying the location of the proposed ROW and a date when proposed ROW will go into effect. If an easement is used in lieu of a ROW, a registered easement plat must be provided. Tax maps with accurate ROW information can be accessed at <http://cagisonline.hamilton-co.org/cagisonline/index.html> . In the “address” pull-down, choose “tax maps”, type in the book and page; e.g.: 194-12, hit “go” then click on the red arrow by the .pdf icon.
- 14) The Center Line, names of streets and edges of pavement must be shown and labeled.
- 15) Show accurately and label the main being tapped and its size.
- 16) Show all easement boundaries in the area of the property if applicable.
- 17) Show fire hydrant heads, valves & leads.
- 18) Include on the plan sheet a copy of the appropriate approved and signed GCWW standard meter setting detail drawing. The most current signed, standard drawings can be found at <http://www.cincinnati-oh.gov/water/permits-construction/records-services/> in .pdf and .tiff formats, or hard copies of these can be obtained from Greater Cincinnati Water Works to be physically copied onto plan sheet. Altered or alternative drawings are not acceptable; only the signed approved standard detail.
- 19) For branches in the streetcar corridor there are additional detail drawings; that must be included on the drawing sheet: 109-1 is to be used for all branches in the streetcar corridor, and if the branch traverses under the rail; use 109-5A or 109-5B whichever is appropriate.
- 20) For development within Hamilton County and outside of the City of Cincinnati corporation limits, the following Hamilton County Traffic Notes must appear on the plan sheet in their entirety:

(Continued Page 7)

HAMILTON COUNTY ENGINEERS SPECIAL PROVISIONS/TRAFFIC NOTES

All construction must conform to: "Driveway Regulations and Pavement and/or Right-Of-Way Opening Provisions for the Unincorporated Area of Hamilton County as Adopted by the Board of Hamilton County Commissioners" with supplements or changes thereto.

The owner shall save harmless the Board of County Commissioners and all its representation from all suits, actions, or claims of any character bought on account of any injuries or damages sustained by any person or persons or property in consequence of this construction project.

Item 614 - Maintaining Traffic

All pavement and/or right-of-way opening must conform to the current addition of the State of Ohio Department of Highway Construction And Material Specifications, with supplements or changes thereto. Also, the owner assumes all responsibilities and liabilities regarding strict adherence to applicable sections for the maintenance of traffic and public safety as set forth in the "Ohio Manual of Uniform Traffic Control Devices for Streets and Highways." All traffic control devices must be in place prior to starting construction.

When the application has been reviewed, field verified, and the drawing meets all of the 20 above requirements, as applicable, you will be asked to provide **4** copies of the final plan sheet.

For large branches from the time of official application to installation, the average length of process time is 90 days; weather & environment conditions, main and branch maintenance & repair needs, and application numbers all impact this average time upward and downward. This is not a waiting period or guaranteed projected time-frame; it is an average projected length of time the course of this process takes.

Rates for Installation of Water Service Branches

Pursuant to the City Manager's authority as set forth in section 40 1-94 of the Cincinnati Municipal Code, the rates described below shall apply to the installation of water service branches, effective May 20, 2015.

Class	3/4"	1"	1-1/2"	2"	4"	6"	8"	10"
Any Street	\$2,775	\$2,820	\$3,020	\$4,540	\$7,950	\$8,245	\$9,700	\$10,345
Unimproved	\$1,960	\$2,235	\$2,360	\$3,860	\$6,570	\$6,705	\$7,310	\$7,905
Restricted	\$2,730	\$2,760	\$2,965	\$4,450	\$6,340	\$6,405	\$6,805	\$7,925
Subdivision	\$390	\$415	\$525	\$715	\$1,665	\$1,805	\$2,195	\$2,670

Domestic or Irrigation portion of Dual or Tri-Service Branch: **3/4"-\$830, 1"-\$955, 1-1/2"-\$1,100, 2"-\$1,265.**

Additional charges:

1. Add \$80 for a STOP BOX or \$120 for a ROADWAY BOX where required by GCWW.
2. Add \$300 to the cost of a branch to be installed in a STATE HIGHWAY.
3. Add \$2,455 for a branch 4" or larger on a 16" main; Add \$2,685 for a branch 4" or larger on a 20" main.
4. Add \$2,880 for each branch larger than 10".

5. Add \$350 for each branch 4" or larger within the City of Cincinnati, plus an additional permit fee for restricted street.

Special Notes:

- A) Branches installed at other than normal hours as required by the Customer or governing authority will require an additional overtime charge.
- B) Street opening permits shall be obtained by Water Works' Contractor except when the applicant must perform preparatory work with the right of way as required by the Water Works or governing authority.
- C) A restricted street is one in which the governing authority will not permit excavation in the street paving. Where a special condition is deemed by Water Works to be present, restricted prices will apply to branches and the applicant will be responsible for the full cost of the work that exceeds the restricted price. Special conditions as determined by the greater Cincinnati Water Works which prohibit or prevent normal branch installations may include but are not limited to culvert, creek or rail crossings. The applicant shall perform all necessary excavations, tunneling, boring/casing and final restoration. Greater Cincinnati Water Works will perform all service branch work and backfill excavation at the water main. Backfilling of the boring pit must be done by the applicant. In some cases it may be necessary to install a stop cock in a position other than the property line. This point will be determined by the Water Works. Notwithstanding the above, where cathodic protection is required by Water Works, the applicant will be responsible for 40% of the total cost of materials and installation that exceeds the restricted price, and the Water Works will perform all work, including the installation of steel casing.
- D) GCWW directed Plan 4 water main extension branch sales projects will use the Unimproved Street prices at GCWW discretion.

Construction Water Prices

	Cincinnati	Incorporated Hamilton Co. Clermont Co.	Unincorporated Hamilton Co.	Arlington Hts. Bulter Co. Mason Warren Co.	Venice Gardens	Cubic Feet
1 Family	\$118.50	\$148.00	\$159.00	\$170.50	\$244.00	50,000
2 Family	\$177.75	\$222.00	\$238.50	\$255.75	\$366.50	75,000
3 Family	\$207.38	\$259.00	\$287.25	\$298.38	\$427.00	87,500

Valve Prices

Size	MJ Gate	CJ Gate	MJxFlange tapping	CJxFlange tapping	FLGxMJ
4	\$334.69	\$343.71	\$422.20	\$444.67	\$319.83
6	\$427.34	\$452.37	\$596.05	\$604.50	\$427.34
8	\$680.12	\$686.85	\$885.43	\$916.18	\$667.54
10	\$1,060.44				\$1,060.44

12	\$1,341.81	\$1,390.86	\$2016.08	\$1,679.67	\$1,280.62
----	------------	------------	-----------	------------	------------

Meter Prices

Meter Size	Couplings Flanges	Encoder	Insulator Couplings
5/8"	\$8.78/ea standard \$12.53/ea short	\$233*	
3/4"	\$9.94/ea standard \$9.94/ea short	\$268*	\$26.31/ea
1"	\$15.30	\$305*	\$38.72
1-1/2"	\$43.72 male \$40.46 female	\$455*	\$79.84
2"	\$53.08 male \$52.83 female	\$520*	\$139.05
2"		\$922*	Turbine
3"		\$2,284*	Compound or Turbine
4"		\$3,688*	Compound, Turbine or Fire
4"		\$6,000*	Protectus Assembly
6"		\$5,427*	Compound, Turbine or Fire
6"		\$8,000*	Protectus Assembly
8"		\$4,229*	Turbine
8"		\$5,844*	Fire Assembly
8"		\$11,336*	Protectus Assembly
10"		\$6,900*	Turbine
10"		\$7,522*	Fire Assembly
10"		\$15,890*	Protectus Assembly
12"		\$11,817	Turbine
16"		\$13,417	Turbine
20"		\$17,690	Turbine

(* INCLUDES METER INTERFACE UNIT)

No more than one pair of couplings or flanges will be sold per each new meter purchase.

Material Prices

Item	Cost	Item	Cost
3/4 curb stop	\$56.22	4 x 1 service saddle	\$82.02
1" curb stop	\$76.73	4 x 1 1/2 service saddle	\$95.65
1 1/2 curb stop	\$167.61	4 x 2 service saddle	\$104.13
2 " curb stop	\$272.88	6 x 1 1/2 service saddle	\$110.46
curb box	\$41.24	6 x 2 service saddle	\$121.36
roadway boxes	see page 9	8 x 1 1/2 service saddle	\$125.88
3/4 ferrule	\$37.69	8 x 2 service saddle	\$137.04
1" ferrule	\$48.36	10 x 1 1/2 service saddle	\$162.69
1 1/2 ferrule	\$104.68	10 x 2 service saddle	\$174.74
2" ferrule	\$183.27	1 1/2 insulator couplings	\$79.84
3/4 insulator coupling	\$26.31	2" insulator coupling	\$139.05
1" insulator coupling	\$48.36		

Meter Size	Laying Length	Ford Yoke Sizes	
		Size	Man #
5/8"	7 1/2"	5/8"	501
3/4"	9"	5/8 x 3/4"	502
1"	10 3/4"	3/4"	503
1 1/2"	13"	1"	502
2"	17"		
3"	24"		
4"	29"		
6"	36"		
8"	42"		

The following guidelines are to be used in determining when to use service saddles:

Branch Size	Cast or Ductile Iron Pipe Size
3/4"	No saddle required on any size
1"	Use saddle on 3" and 4" only
1 1/2"	Use saddle on 3", 4", and 6" only
2"	Use saddle on 3", 4", 6", 8", and 10" only

Service saddles are required for all sizes of service branches installed on AC pipe. Service saddles will not be permitted where not required by the above regulations.

Curb Boxes

- 1.) Curb boxes required on all settings
- 2.) Insulator couplings are required on all branches.
- 3.) There are only three valve manufacturers that have accepted valves at this time:
 - a. Ford (B-11 series)
 - b. McDonald 6101
 - c. Jones J-1905

Roadway Box Parts

Item	Cost	Item	Cost
Box, Valve, Roadway, Hood Only	\$21.35	Box, Valve, Iron, Hood Only	\$106.40
Box, Valve, Roadway, Lid Only	\$20.08	Box, Valve, Iron, Lid Only	\$26.60
Box Valve, Roadway, Ring Only	\$18.78	Box, Valve, Iron, Telescope	\$179.55
Box Valve, Roadway, Telescope	\$23.21		
Box, Valve, Plastic, Hood Only	\$30.64	Box, Valve, Plastic, Lid Only	\$47.10
Box, Valve, Plastic, Ring Only	\$79.99	Box, Plastic, Telescope Only	\$79.24

Mason Branch Costs

Size	3/4"	1"	1 1/2"	2"	4"	6"	8"	10"
Any Street	\$2,775	\$2,820	\$3,020	\$4,540	\$7,950	\$8,245	\$9,700	\$10,345
Unimproved	\$1,960	\$2,235	\$2,360	\$3,860	\$6,570	\$6,705	\$7,310	\$7,905
Restricted	\$2,730	\$2,760	\$2,965	\$4,450	\$6,340	\$6,405	\$6,805	\$7,925
Subdivision	\$390	\$415	\$525	\$715	\$1,665	\$1,805	\$2,195	\$2,670

- 1.) Dual service installed by GCWW: 3/4" - \$830.00, 1"- \$955.00, 1 1/2"- \$1100.00, 2"- \$1265.00
- 2.) Add \$80.00 for curb box or \$120.00 for roadway box where required by GCWW.
- 3.) Add \$300.00 for cost of branch to be installed in a state highway.
- 4.) Add \$2455.00 for a branch 4" or larger on 16" main; Add \$2685.00 for a branch 4" or larger on a 20" main.
- 5.) Add \$2880.00 for each branch size larger than a 10".
- 6.) Branches installed at other than normal hours as required by customer will require additional overtime charge.
- 7.) Street opening permits shall be obtained by GCWW contractor except when applicant must perform preparatory work within the right of way as required by the GCWW. In this case the applicant shall obtain the street opening permit.
- 8.) Standard prices do not apply to restricted prices or special conditions. A restricted street is one in which the governing entity will not permit excavation in the street paving. Special conditions as determined by the GCWW which prohibit or prevent normal branch installation may include but are not limited to culvert, creek or railroad. In such cases restricted rate prices will apply to branches. The applicant shall perform all excavation, tunneling, boring/casing and final restoration. GCWW will perform all service branch work and backfill excavation at water main. Boring pit backfill must be performed by the applicant. In some cases it

may be necessary to install a stop cock in a position other than the property line. This location will be determined by the GCWW.

- 9.) There will be a **\$1,070.00** system fee added to all branch costs at time branch is purchased.

Mason Meters			Mason Commercial Meter Expansion Fee	
Size	Type	Cost	Expansion Fee	Total
5/8"		\$358.00		
3/4"		\$358.00	\$4,370.00	\$4,690.00
1"		\$305.00	\$4,617.00	\$4,922.00
1 1/2"		\$455.00	\$7,723.00	\$8,178.00
2"		\$520.00	\$12,341.00	\$12,861.00
2"	turbine	\$922.00	\$12,341.00	\$13,263.00
3"	compound/tur	\$2,284.00	\$27,877.00	\$30,161.00
4"	compound/tur	\$3,688.00	\$53,032.00	\$57,720.00
4"	protectus	\$6,000.00	\$53,032.00	\$59,032.00
6"	compound/tur	\$5,427.00	\$118,190.00	\$123,617.00
6"	protectus	\$8,000.00	\$118,190.00	\$126,190.00
8"	turbine	\$4,229.00	\$196,991.00	\$201,220.00
8"	fire assembly	\$5,844.00	\$196,991.00	\$202,479.00
8"	protectus	\$11,336.00	\$196,991.00	\$208,327.00
10"	turbine	\$6,900.00		
10"	fire assembly	\$7,522.00		
10"	protectus	\$15,890.00		
12"	turbine	\$11,817.00		
16"	turbine	\$13,417.00		
20"	turbine	\$17,690.00		

- 1.) There will be an additional system expansion fee on all residential meters of \$4,441.00 per family unit.
- 2.) For special purpose apartment projects, such as those intended for the elderly, containing one or two room efficiency units, with occupancy rigidly controlled and equipped with only one set of kitchen and bath fixtures, the expansion charge, tap size and meter size shall be seventy-five percent (75%) of size required in chart for multi-family units.
- 3.) For trailer parks, where more than one trailer is served by the same meter, the expansion charge, tap size and meter size shall be determined as apartments.
- 4.) For purposes of water system expansion fees the following facilities shall be considered businesses and pay fees as set forth for commercial meter fees: convalescent homes, hospitals, nursing homes, group homes and housing of elderly other than those described in #2.

Domestic Branch and Meter Sizing Tables
Fixture Units Table

Fixture Type	Value @35 PSI	Fixture Type	Value @35 PSI
Bathtub	8	Urinal: Pedestal flush valve	35
Bedpan washers	10	Wall and stall	12
Combination sink and tray	3	Trough 2 ft unit	2
Dental Unit	1	Wash sink (each set of faucets)	4
Dental Lavatory	2	Water Closet: flush valve	35
Drinking Fountain (cooler)	1	Tank Type	3
Drinking Fountain (public)	2	Dishwater: 1/2" connection	4
Kitchen Sink: 1/2" connection	3	Dishwater: 3/4" connection	12
Kitchen Sink: 3/4" connection	7	Washing Machine: 1/2" connection	5
Lavatory: 3/8" connection	2	Washing Machine: 3/4" connection	12
Lavatory: 1/2" connection	4	Washing Machine: 1" connection	25
Laundry Tray: 1/2" connection	3	Hose connecting(wash down) 1/2"	6
Laundry Tray: 3/4" connection	7	Hose connection(washdown) 3/4"	10
Shower head (shower only)	4	Hose (50 ft long wash down) 1/2"	6
Service Sink: 1/2" connection	3	Hose (50 ft long wash down) 5/8"	9
Service Sink: 3/4" connection	7	Hose (50 ft long wash down) 3/4"	12

Value of a number of units by simply multiplying.

Minimum Requirements: Residential

Building size	Tap	Meter	Maximum Operating Capacity	Recommended Operating Capacity
1 family	3/4	5/8	20 gpm	10 gpm
	3/4	3/4	30 gpm	15 gpm
2-6 family	1	3/4	30 gpm	15 gpm
7-12 family	1	1	50 gpm	25 gpm
13-20 family	1 1/2	1	50 gpm	25 gpm
20-50 family	1 1/2	1 1/2	100 gpm	50 gpm
51-75 family	2	1 1/2	100 gpm	50 gpm
76-120 family	2	2	160 gpm	80 gpm
121-175 family	4	3	320 gpm	150 gpm
176-250 family	4	4	500 gpm	250 gpm
251-350 family	6	4	500 gpm	250 gpm
351-500 family	6	6	1000 gpm	500 gpm

Calculate trailer parks @ 75% capacity, Calculate hotels/motels @ 50% capacity

Minimum Requirements: Commercial

Water demand Min. and Max. Flows	Branch Size	Meter Size
0.25 to 20	3/4	5/8
0.50 to 30	3/4	3/4
0.50 to 30	1	3/4
0.75 to 50	1	1
0.75 to 50	1.5	1
1.50 to 100	1.5	1.5
1.50 to 100	2	1.5
2.0 to 160	2	2
0.50 to 320	4	3
0.75 to 500	4	4
0.75 to 500	6	4
1.5 to 1000	6	6
1.5 to 1000	8	6
50.0 to 2400	8	8
75.0 to 3800	10	10
120.0 to 5000	12	12

BRANCH MATERIAL REFERENCE DATA

Branch Number	Date		Branch Number	Date
1	1837	Subject to have Gooseneck or Basket Ferrule	150000	1950
5000	1855		155000	1951
10000	1857		160000	1952
15000	1866		165000	1953
20000	1873		170000	1955
25000	1881		175000	1956
30000	1885		175615	
35000	1888		Branch & meter #'2 same from here on	
40000	1892		180000	1957
45000	1895		185000	1958
50000	1900		190000	1959
55000	1904		195000	1960
60000	1908		200000	1961
65000	1910		205000	1962

70000	1913		207160	1 st branch w/no curb box required
75000	1915		210000	1963
80000	1918		215000	1964
85000	1922		220000	1965
88000	All prior branches are lead		225000	1966
90000	1924		225420	First & only plastic branch (2")
95000	1926	Brass	230000	1967
100000	1927		240000	1972
101808	1928		250000	1976
All branches after this are copper			260000	1983
110000	1930		270000	1988
115000	1933		275000	Meters inside AMR C/B
120000	1935		279500	F/B with C/B
125000	1938		280000	1966
Mason Branches				
130000	1940		297000	2002
135000	1942		299401	2002
140000	1946		300000	2005
145000	1948		205000	2005